

- NOTE 1. HYDRANTS SHALL BE THE EAST BAY CALIFORNIA FIRE HYDRANT MANUFACTURED UNDER LICENSE WITH THE EAST BAY MUNICIPAL UTILITY DISTRICT AS MANUFACTURED BY CLOW OR APPROVED EQUAL.
  - 2. THE STEM PLUG CLOSEST TO THE CURB SHALL BE 24" MIN. FROM THE CURB FACE. FOR MONOLITHIC SIDEWALKS, 36" MIN. WIDE CLEARANCE IS REQUIRED FOR ACCESSIBILITY.
  - 3. HYDRANTS SHALL BE PAINTED KEL-GUARD ENAMEL SAFETY YELLOW NO. 1700-63 MANUFACTURED BY KELLY-MOORE PAINT CO. OR APPROVED EQUAL.
  - 4. SET HYDRANT TO GRADE SUCH THAT LOWEST STEM PLUG IS 18" MIN. ABOVE SIDEWALK OR 20" MIN. ABOVE FINISH GROUND IN PLANTER AREAS.

	CITY OF FREMONT STANDARD DETAILS					DATE APPROVED BY CITY COUNCIL 04/11/06  RESOLUTION NO. 2006-31		
NO.	REVISED	DATE	FIRE HYDRANT				Nam Hughen	
REVISIONS							CITY ENGINEER	
FILE NO.		SCALE	DRAWN	CHEC	CKED	DATE	DWG NO.	
SD-3	SD-34-06.DWG		DC	;	KC	03/09/06	SD-34	1 of 1